



Certificate of Compliance

Certificate: 70009242 (221421)

Master Contract: 221421

Project: 70040709

Date Issued: 2015-11-20

Issued to: Connection Technology Center, Inc.
7939 Rae Boulevard
Victor, NY 14564
USA

Attention: Colin Walker

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Nicholas
Cameron
Nicholas Cameron

PRODUCTS

CLASS - C225802 - PROCESS CONTROL EQUIPMENT-For Hazardous Locations-

CLASS - C225882 - PROCESS CONTROL EQUIPMENT-For Hazardous Locations - Certified to US Standards

Class I, Division 2, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III; T3C

Ex nA IIC T3 Gc

Class I, Zone 2, AEx nA IIC T3 Gc

Transducer Sensor – AC9** Series – Temperature Code T3/T3C; ambient temperature range -40°C to +121°C

Transducer Sensor – TA9** Series – Temperature Code T3/T3C; ambient temperature range -40°C to +121°C

Electrical Ratings are: $U_i = 28\text{VDC}$, $I_i = 120\text{mA}$, $P_i = 100\text{mW}$, $C_i = 0\text{nF}$, $L_i = 51\mu\text{H}$

Condition of Certification:

- i. Class I, Division 2 / Zone 2 when installed using an approved Zone 2 / Division 2 rated cable in accordance with the CEC or the NEC.
- ii. Suitability of final installation is to be determined by the authority having local jurisdiction.

Note: Asterisks “**” denotes alpha-numeric characteristic denoting mounting configurations, connector types or approval agencies per drawings INS10038.



Certificate: 70009242

Project: 70040709

Master Contract: 221421

Date Issued: 2015-11-20

CLASS 2258 04 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations
CLASS 2258 84 - PROCESS CONTROL EQUIPMENT - Intrinsically Safe Entity - For Hazardous Locations -
CERTIFIED TO US STANDARDS

Class I, Division 1, Groups A, B, C and D; Class II, Division 1, Groups E, F and G; Class III; T3/T4

Ex ia IIC T3/T4 Ga

Class I, Zone 0, AEx ia IIC T3/T4 Ga

Transducer Sensor – AC9** Series – Temperature Code T4; ambient temperature range -40°C to +80°C

Transducer Sensor – AC9** Series – Temperature Code T3; ambient temperature range -40°C to +121°C

Transducer Sensor – TA9** Series – Temperature Code T3; ambient temperature range -40°C to +121°C

For the AC9** Series:

When not provided with Integral Cable:

- Intrinsically safe with Entity Parameters – $U_i = 28\text{VDC}$, $I_i = 120\text{mA}$, $P_i = 1\text{W}$, $C_i = 63.036\text{nF}$, $L_i = 0\mu\text{H}$

When provided with a maximum of 200 feet (61m) of Integral Cable:

- Intrinsically safe with Entity Parameters – $U_i = 28\text{VDC}$, $I_i = 120\text{mA}$, $P_i = 1\text{W}$, $C_i = 72.836\text{nF}$, $L_i = 42\mu\text{H}$

For the TA9** Series:

When not provided with Integral Cable:

- Intrinsically safe with Entity Parameters – $U_i = 28\text{VDC}$, $I_i = 120\text{mA}$, $P_i = 1\text{W}$, $C_i = 1.5\text{nF}$, $L_i = 0\mu\text{H}$

When provided with a maximum of 1600 feet (488m) of Integral Cable:

- Intrinsically safe with Entity Parameters – $U_i = 28\text{VDC}$, $I_i = 120\text{mA}$, $P_i = 1\text{W}$, $C_i = 80.2\text{nF}$, $L_i = 336\mu\text{H}$

Note: Asterisks “**” denotes alpha-numeric characteristic denoting mounting configurations, connector types or approval agencies per drawings INS10038. AC Series has 1, 2, and 3 channel options and the TA Series uses 2 channel options. 1st channel uses a 1 channel barrier, 2nd channel uses the second channel barrier, and 3rd channel sensor uses 1 of each.



Certificate: 70009242

Project: 70040709

Master Contract: 221421

Date Issued: 2015-11-20

APPLICABLE REQUIREMENTS

CSA C22.2 No. 0-10	- General Requirements - Canadian Electrical Code Part II
CSA C22.2 No. 94-M1991 (R2011)	- Special Purpose Enclosures
CSA C22.2 No. 142-M1987 (R2014)	- Process Control Equipment
CSA C22.2 No. 213-M1987 (R2013)	- Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations
CAN/CSA C22.2 No. 60079-0-11	- Electrical apparatus for explosive gas atmospheres; Part 0: General requirements
CAN/CSA C22.2 No. 60079-11-14	- Electrical apparatus for explosive gas atmospheres; Part 11: Intrinsic safety "i"
CAN/CSA C22.2 No. 60079-15:12	- Part 15: Equipment Protection by Type of protection "n"
UL Standard 50, Eleventh Edition	- Enclosures for Electrical Equipment
UL Standard 508, Seventeenth Edition	- Industrial Control Equipment
UL Standard 913, Eighth Edition	- Intrinsically Safe Apparatus and Associated Apparatus for use in Class I, II, III, Division 1, Hazardous (Classified) Locations.
UL Standard 60079-0, 6 th Edition	- Part 0: General Requirements
UL Standard 60079-11, 6 th Edition	- Electrical apparatus for explosive gas atmospheres; Part 11: Intrinsic safety "i"
UL Standard 60079-15, 4 th Edition	- Part 15: Equipment Protection by Type of Protection "n"
ANSI/ISA-12.12.01-2013	- Non-Incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations



Supplement to Certificate of Compliance

Certificate: 70009242 (221421)

Master Contract: 221421

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70040709	2015-11-20	Update to report 70009242 to have the entity parameter for current increased to 120mA from 100mA.
70009242	2015-05-04	New Certification of Sensors, Models ACXXX Series and TXXX Series as IS for C1D1, C1D2 Groups ABCD, Class II and Class III and Ex nA IIC and Ex ia IIC for Zones.