



Connection Technology Center  
7939 Rae Blvd  
Victor, NY 14564  
(585) 924-5900

8/24/2020

### Safety Integrity Level (SIL) Certificate of Compliance

The following parts mentioned are suitable for use in safety related systems up to and including SIL 2 in accordance with IEC 61508. The mean time to failure was calculated using the IEC 62380 protection method. Since the mode of operation is continuous, failures per hour is used to determine the Safety Integrity Level (SIL).

**Parts tested:**

Part Number	Description	Failures/Hour
AC102 SERIES	Multi-Purpose Accelerometer, Top Exit Connector/Cable, 100 mV/g	6.81392E-08

Certified by

Colin Walker  
Quality Assurance and Regulatory Affairs Manager