

United Kingdom

IECEx Certificate of Conformity

	IEC Certification Sy	LECTROTECHNICAL COMMISSION ystem for Explosive Atmospheres s of the IECEx Scheme visit www.iecex.com	
Certificate No.:	IECEx SIR 15.0060X	Page 1 of 4	Certificate history:
Status:	Current	Issue No: 1	Issue 0 (2015-06-17)
Date of Issue:	2019-11-05		
Applicant:	CTC - Connection Technology Ce 7939 Rae Blvd. Victor New York 14564 United States of America	enter, Inc.	
Equipment:	Transducer Sensors/AC9** Series	s and TA9** Series	
Optional accessor	'y:		
Type of Protection	i: Intrinsically Safe		
Marking:	Ex ia IIC T3 -T4 Ga T3: Ta40°C to +121°C T4: Ta40°C to +80°C		
Approved for issue Certification Body:	e on behalf of the IECEx	Neil Jones	
Position:		Certification Manager	
Signature: (for printed versior	n)		
Date:			
2. This certificate	e and schedule may only be reproduced in is not transferable and remains the prop d authenticity of this certificate may be ve		
Certificate issu	ied by:		
	ation Service den Industrial Park eeside, CH5 3US		



IECEx Certificate of Conformity

Certificate No .:	IECEx SIR 15.0060X	Page 2 of 4
Date of issue:	2019-11-05	Issue No: 1
Manufacturer:	CTC - Connection Technology Center, Inc. 7939 Rae Blvd. Victor New York 14564 United States of America	
Additional manufacturing locations:		
the IEC Standard list assessed and found t	ed as verification that a sample(s), representative of production below and that the manufacturer's quality system, relating to the co comply with the IECEx Quality system requirements. This cert s, IECEx 02 and Operational Documents as amended	Ex products covered by this certificate, was
STANDARDS : The equipment and a to comply with the foll	ny acceptable variations to it specified in the schedule of this ce lowing standards	ertificate and the identified documents, was found
IEC 60079-0:2017 Edition:7.0	Explosive atmospheres - Part 0: Equipment - General requirer	nents
IEC 60079-11:2011 Edition:6.0	Explosive atmospheres - Part 11: Equipment protection by intr	insic safety "i"
	This Certificate does not indicate compliance with safety ar other than those expressly included in the Stand	
TEST & ASSESSME A sample(s) of the eq	NT REPORTS: uipment listed has successfully met the examination and test re	quirements as recorded in:
Test Reports:		
GB/SIR/ExTR15.017	1/00 GB/SIR/ExTR19.0258/00	
Quality Assessment F	Report:	
CA/CSA/QAR08.001	1/08	



IECEx Certificate of Conformity

Certificate No.: IECEx SIR 15.0060X
Date of issue: 2019-11-05

Page 3 of 4

Issue No: 1

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

Vibration sensors are used for acceleration measurement by means of piezo-electric device. The piezo-electric is subjected to compression pressure from a mass which produce a voltage in proportion to the acceleration. The voltage is then amplified by internal electronic circuitry. This can also be integrated within the amplifier board to product a velocity output, referred to with a VE prefix. For the Loop Power series (LP prefix), the output is converted to a 4-20 mA. These sensors can be used in conjunction with a temperature board to provide the temperature of the environment the sensor is contained within this configuration is referred to with a TA prefix. For the negative voltage and LP series sensor, an external power source is required necessitating an extra conductor wire. The sensors are mounted to the surface of the desired surface via a threaded bolt or by other means to be approved of by the authority having jurisdiction.

Refer to the Annexe for additional information.

SPECIFIC CONDITIONS OF USE: YES as shown below: Refer to the Annexe for the Specific Conditions of Use.



IECEx Certificate of Conformity

Certificate No.: IECEx SIR 15.0060X

Page 4 of 4

Date of issue: 2019-11-05

Issue No: 1

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

This issue, Issue 1, recognises the following changes: refer to the certificate annexe to view a comprehensive history:

- 1. Assessment of new accelerometers' added models. The description was amended to recognise these new models. The Special Conditions of Use and Conditions of Manufacture were also amended.
- 2. Addition of the full nomenclature for all accelerometers' models to the report.
- 3. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, IEC 60079-0:2011 Ed. 6 was replaced by IEC 60079-0:2017 Ed. 7
- 4. Changing all accelerometers assessed models' entity parameters to match corresponding Schematics.
- 5. Updating Schematics to reflect applied changes, updating nameplates and instruction manual.
- 6. Excluding accelerometers' obsolete models and those of different marking.
- 7. The ambient temperature range was corrected to include the T4 marking which had previously been omitted.

Annex:

IECEx SIR 15.0060X Annexe Issue 1.pdf

Annexe to:IECEx SIR 15.0060X Issue 1Applicant:CTC - Connection Technology Center, IncertificationApparatus:Transducer Sensors/AC9** Series and
TA9** Series

In terms of connectors and cables, involved models overlap slightly as shown below:

A- Refer to DWG INS10012 for connections' details:

2 Pin Vibration Sensors Connected to 1 Single Channel Barrier	 3 Pin Vibration Sensors Connected to 1 Dual Channel Barrier or 2 Single Channel barrier 	 4 Pin Vibration Sensors Connected to 1 Dual Channel Barrier & 1 Single Channel barrier or 3 Single Channel barrier
AC91 Series	TA91 Series	AC957 Series
LP81 Series	AC979 Series	AC972 Series
LP91 Series	AC82 Series	AC980 Series
VE9 Series	AC86 Series	AC981 Series
AC83 Series		TA82 Series
AC90 Series		
LP80 Series		
LP90 Series	INTERNAL LA LAN ANTERNAL LA L	
AC970 Series	A Date of the second se	
AC974 Series	do ziter	- MACRONE LANGE THE AVECT OF A CONTRACT OF A
AC976 Series		
		NATIONALISAT

- Standard accelerometers and velocity sensors have 2 pins and uses 2 wire cable, 1 wire is for the sensing element and 1 common.
- The Biaxial, designated sensors have 3 pins and uses 3 wire cables. For the biaxial sensor 2 wires are for the different sensing elements and 1 common. For temperature, 1 wire is for signal, 1 for temperature, 1 shared common. For negative voltage and low power, 1 wire is for signal, 1 for power, and 1 for ground.
- The Triaxial designated sensors have 4 pins and a 4 wire cable. For Triaxial 1 wire for each of the 3 sensing elements and 1 for common. For low power with temperature, 1 wire is for signal, 1 for temperature, 1 for power and 1 for shared common.

B- For each model maximum allowable integral cable length as shown below:

1- For models utilising blocking diodes the maximum cable length would be 1600 ft (488 m)

2- For models not utilising blocking diodes the maximum cable length would be 200 ft (61 m)

Models With Integral Cables	Maximum Integral Cable Length
AC901-XR, AC902-XR	200 ft (61 m)
AC903-XR, AC904-XR	200 ft (61 m)
AC905-XR, AC906-XR	200 ft (61 m)

Date: 05 November 2019

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom Tel: +44 (0) 1244 670900 Email: <u>ukinfo@csagroup.org</u>

www.csagroupuk.org

Web:

IECEx SIR 15.0060X Issue 1

Applicant:



Apparatus:

Transducer Sensors/AC9** Series and TA9** Series

Models With Integral Cables	Maximum Integral Cable Length
AC970-XR THROUGH AC979-XR	200 ft (61 m)
AC980-XR THROUGH AC989-XR	
AC812-XR, AC814-XR	200 ft (61 m)
AC822-XR, AC824-XR	
AC865-XR, AC866-XR	200 ft (61 m)
TA81-XR, TA82-XR	200 ft (61 m)
AC911-XR, AC912-XR, AC913-XR, AC914-XR,	1600 ft (488 m)
AC915-XR, AC916-XR, AC917-XR, AC918-XR	
AC961-XR, AC952-XR, AC963-XR, AC964-XR,	1600 ft (488 m)
AC965-XR, AC966-XR, AC967-XR, AC968-XR	
TA91*-XR	1600 ft (488 m)
LP80*-XR, LP81*-XR,	1600 ft (488 m)
LP90*-XR, LP91*-XR	
LP85*-XR, LP86*-XR,	1600 ft (488 m)
LP95*-XR, LP96*-XR	
VE901-XR, VE902-XR	1600 ft (488 m)

C- For models specified with integral cables the following list to be utilised:

Part Number	Capacitance	Resistance	Inductance
CB102	48.0 pF/ft	10.0Ω/1000ft	0.081µH/ft
CB103*	49 pF/ft	9.7Ω/1000ft	0.047µH/ft
CB193*	49 pF/ft	9.7Ω/1000ft	0.047µH/ft
CB111	45.0 pF/ft	10.0Ω/1000ft	0.084µH/ft
CB190*	36 pF/ft	9.5Ω/1000ft	0.19µH/ft
CB206	35 pF/ft	42Ω/1000ft	0.062µH/ft
CB212	41 pF/ft	13.0Ω/1000ft	0.092µH/ft
CB191*	44.13 pF/ft	11.9Ω/1000ft	0.18µH/ft
CB192*	37.15 pF/ft	16.41Ω/1000ft	0.20µH/ft
CB218	27.9 pF/ft	15.4Ω/1000ft	0.21µH/ft

Accelerometers' nomenclature have been adjusted to present the distinguished type of enclosure and PCB enclosed.

A- Previously assessed accelerometers models taking into consideration the new designations: (Used for Class I Division 1, Zone 0 and Zone 1)

Item number	Model Nomenclature	Entity Parameters		
AC Series with and without Integral Cables (DWG INS 10106)				
1- Without integral cable	AC901-1R, AC902-1R	Ui = 28VDC Ii = 120mA Pi = 1W Ci = 11.51 nF Li = 0 uH		

Haward	den, CH5 3US, United Kingdom
Tel:	+44 (0) 1244 670900
Email:	ukinfo@csagroup.org
Web:	www.csagroupuk.org

IECEx SIR 15.0060X Issue 1

Applicant:



Apparatus: Transducer Sensors/AC9** Series and TA9** Series

Item number	Model Nomenclature	Entity Parameters
2- With integral cable	AC901-XR, AC902-XR	Ui = 28VDC
5		li = 120mA
		Pi = 1W
		Ci = 51.7 nF
		Li = 336 µH
3- Without integral cable	AC903-1R, AC904-1R	Ui = 28VDC
		li = 120mA
		Pi = 1W
		Ci = 24.02 nF
		Li = 0 μΗ
4- With integral cable	AC903-XR, AC904-XR	Ui = 28VDC
		li = 120mA
		Pi = 1W
		Ci = 64.02nF
		Li = 336 µH
5- Without integral cable	AC905-1R, AC906-1R	Ui = 28VDC
_		li = 120mA
		Pi = 1W
		Ci = 64.02nF
		Li = 336 µH
6- With integral cable	AC905-XR, AC906-XR	Ui = 28VDC
		li = 120mA
		Pi = 1W
		Ci = 80.85nF
		Li = 336 µH
7- Without integral cable	AC911-1R, AC912-1R, AC913-	Ui = 28VDC
	1R, AC914-1R,	li = 120mA
	AC915-1R, AC916-1R, AC917-	Pi = 1W
	1R, AC918-1R	Ci = 28nF
		Li = 0µH
8- With integral cable	AC911-XR, AC912-XR, AC913-	Ui = 28VDC
	XR, AC914-XR,	li = 120mA
	AC915-XR, AC916-XR, AC917-	Pi = 1W
	XR, AC918-XR	Ci = 80.4nF
		Li = 336µH
9- Without integral cable	AC961-1R, AC952-1R, AC963-	Ui = 28VDC
	1R, AC964-1R,	li = 120mA
	AC965-1R, AC966-1R, AC967-	Pi = 1W
	1R, AC968-1R	Ci = 0nF
		Li = 0µH
10- With integral cable	AC961-XR, AC952-XR, AC963-	Ui = 28VDC
	XR, AC964-XR,	li = 120mA
	AC965-XR, AC966-XR, AC967-	Pi = 1W
	XR, AC968-XR	Ci = 80.4nF
		Li = 336µH

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom +44 (0) 1244 670900 Tel: Email: ukinfo@csagroup.org Web: www.csagroupuk.org

IECEx SIR 15.0060X Issue 1

Applicant:



Transducer Sensors/AC9** Series and Apparatus: TA9** Series

Item number	Model Nomenclature	Entity Parameters
11- Without integral cable	AC970-1R THROUGH AC979-	Ui = 28VDC
5	1R	li = 120mA
	AC980-1R THROUGH AC989-	Pi = 1W
	1R	Ci = 28nF
		Li = 0µH
12- With integral cable	AC970-1R THROUGH AC979-	Ui = 28VDC
	1R	Ii = 120mA
	AC980-1R THROUGH AC989-	Pi = 1W
	1R	Ci = 40nF
		Li = 40.2µH
TA Series with and without Integ	ral Cables (DWG INS 10109)	
13- Without integral cable	TA91*-1R	Ui = 28VDC
		li = 120mA
		Pi = 1W
		Ci = 1.5nF
		Li = 40.2µH
14- With integral cable	TA91*-XR	Ui = 28VDC
		li = 120mA
		Pi = 1W
		Ci = 82nF
		Li = 336µH

B- New added and assessed accelerometers models including the new designations: (Used for Class I Division 1, Zone 0 and Zone 1)

Item number	Model Nomenclature	Entity Parameters		
AC Series with and without Integral Cables (DWG INS 10106)				
1- Without integral cable	AC812-1R, AC814-1R	Ui = 6VDC		
	AC822-1R, AC824-1R	Ii = 0.5A		
		Pi = 1W		
		Ci = 266nF		
		$Li = 0\mu H$		
2- With integral cable	AC812-XR, AC814-XR	Ui = 6VDC		
	AC822-XR, AC824-XR	Ii = 0.5A		
		Pi = 1W		
		Ci = 278.2nF		
		$Li = 42\mu H$		
3- Without integral cable	AC865-1R, AC866-1R	Ui = -28VDC		
		li = 120mA		
		Pi = 1W		
		Ci = 46nF		
		Li = 0µH		
4- With integral cable	AC865-XR, AC866-XR	Ui = -28VDC		
		li = 120mA		
		Pi = 1W		
		Ci = 58.2nF		
		Li = 42µH		
TA Series with and without Integral Cables (DWG INS 10109)				

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom Tel: +44 (0) 1244 670900 Email: ukinfo@csagroup.org Web: www.csagroupuk.org

IECEx SIR 15.0060X Issue 1

Applicant:



Apparatus:

Transducer Sensors/AC9** Series and TA9** Series

Item number	Model Nomenclature	Entity Parameters		
5- Without integral cable	TA81*-1R, TA82-1R	Ui = 6VDC		
		II = 0.5A		
		Pi = 100mW		
		Ci = 268.5nF		
		$Li = 0\mu H$		
6- With integral cable	TA81-XR, TA82-XR	Ui = 6VDC		
	- , -	II = 0.5A		
		Pi = 100mW		
		Ci = 268.5nF		
		Li = 0µH		
LP Series with and without Int	egral Cables (DWG INS 10 ²			
7- Without integral cable	LP80*-1R, LP81*-1R,	Ui = 28VDC		
	LP90*-XR, LP91*-1X	li = 120mA		
		Pi = 1W		
		Ci = OnF		
		Li = 0µH		
8- With integral cable	LP80*-XR, LP81*-XR,	Ui = 28VDC		
5	LP90*-XR, LP91*-XR	li = 120mA		
		Pi = 1W		
		Ci = 80.4nF		
		Li = 336µH		
9- Without integral cable	LP85*-1R, LP86*-1R,	Ui = 28VDC		
	LP95*-1R, LP96*-1R	li = 120mA		
		Pi = 1W		
		Ci = 0nF		
		$Li = 0\mu H$		
10- With integral cable	LP85*-XR, LP86*-XR,	Ui = 28VDC		
	LP95*-XR, LP96*-XR	li = 120mA		
		Pi = 1W		
		Ci = 80.4nF		
		Li = 336µH		
VE Series with and without Integral Cables (DWG INS 10108)				
11- Without integral cable	VE901-1R, VE902-1R	Ui = 28VDC		
		li = 120mA		
		Pi = 1W		
		Ci = OnF		
		$Li = 0\mu H$		
12- With integral cable	VE901-XR, VE902-XR	Ui = 28VDC		
_		Ii = 120mA		
		Pi = 1W		
		Ci = 80.4nF		
		Li = 336µH		

Specific Conditions of Use

i. All models of the assessed equipment are required to be connected to a properly rated I.S. barrier as per DWG INS10012. The Ui & Ii parameters are the worst case voltage and current from the combination of these barriers, but they cannot appear at the same time. It is the end-users' responsibility to ensure

Sira Certification Service Unit 6 Hawarden Industrial Park,

Unit U nawaruen muustnarr ark,				
Hawarden, CH5 3US, United Kingdom				
Tel:	+44 (0) 1244 670900			
Email:	ukinfo@csagroup.org			
Web:	www.csagroupuk.org			

 Annexe to:
 IECEx SIR 15.0060X Issue 1

 Applicant:
 CTC - Connection Technology Center, Incertification

 Apparatus:
 Transducer Sensors/AC9** Series and TA9** Series

that the combined voltage and current of the connected barriers does not exceed the values of Table A.1 of IEC 60079-11:2011 Ed6.

- ii. Cables of the following part numbers are restricted only for use with sensors of a maximum ambient temperature of + 80°C, The manufacturer shall ensure that the product is marked accordingly:
 - CB103
 - CB190
 - CB191
 - CB192
 - CB193
- iii. Maximum Cable lengths are specified and these maximum values shall not be exceeded as per the following list:

Maximum Integral Cable Length
200 ft (61 m)
200 ft (61 m)
200 ft (61 m)
200 ft (61 m)
1600 ft (488 m)
1600 ft (488 m)
1600 ft (488 m)
1600 ft (488 m)
1600 ft (488 m)
1600 ft (488 m)

- iv. The entity parameters of the vibration sensors and integrated cables shall not be exceeded as per the marked nameplates. Refer to the following controlled documents for details:
 - INS10106
 - INS10107
 - INS10108
 - INS10109

Conditions of Manufacture

- i. The equipment shall be subjected to dielectric strength test using test voltage of 500 VAC applied between circuit and earth for 60 seconds. Alternatively a voltage of 20% higher may be applied for 1 second. There shall be no evidence of flashover or breakdown and the maximum current flowing during the test shall not exceed 5 m A r.m.s. at any time. Refer to IEC 60079-11:2011 Ed. 6 clause 6.3.13.
- ii. Cables of the following part numbers are restricted only for use with sensors of a maximum ambient temperature of + 80°C, The manufacturer shall ensure that the product is marked accordingly:

Page 6 of 8

Sira Certification Service Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

Annexe to:	I	ECEx S	IR 15.0060	X Issue	1	C		G	CSA	
Applicant:	C	CTC - Co	onnection T	echnolo	ogy Center,	, Inc.			CSA GROUP	тм
Apparatus:	-	ransdu A9** S	cer Sensors Feries	s/AC9*	* Series an	d				
i.	CB103	ii.	CB190	iii.	CB191	iv.	CB192	V.	CB193	

Page 7 of 8

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom Tel: +44 (0) 1244 670900 Email: <u>ukinfo@csagroup.org</u> Web: <u>www.csagroupuk.org</u>

Annexe to:	IECEx SIR 15.0060X Issue 1
Applicant:	IECEx SIR 15.0060X Issue 1 CTC - Connection Technology Center, Internet CERTIFICATION
Apparatus:	Transducer Sensors/AC9** Series and TA9** Series

Full certificate change history

This issue, Issue 1, recognises the following changes; refer to the certificate annexe to view a comprehensive history:

- 1. Assessment of new accelerometers' added models. The description was amended to recognise these new models. The Special Conditions of Use and Conditions of Manufacture were also amended.
- 2. Addition of the full nomenclature for all accelerometers' models to the report.
- 3. Following appropriate assessment to demonstrate compliance with the latest technical knowledge, IEC 60079-0:2011 Ed. 6 was replaced by IEC 60079-0:2017 Ed.
- 4. Changing all accelerometers assessed models' entity parameters to match corresponding Schematics.
- 5. Updating Schematics to reflect applied changes, updating nameplates and instruction manual.
- 6. Excluding accelerometers' obsolete models and those of different marking.
- 7. The ambient temperature range was corrected to include the T4 marking which had previously been omitted.

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom Tel: +44 (0) 1244 670900 Email: <u>ukinfo@csagroup.org</u> Web: <u>www.csagroupuk.org</u>